



Attachment C – Equipment List
 RFx No. 3000006116 Title: Fire Systems Maintenance
 LHH – Pinecrest Supports & Services Center

SCHEDULE I
PINECREST SUPPORTS AND SERVICES CENTER
FIRE ALARM SYSTEMS

LOCATION	SYSTEM	LOCATION	SYSTEM
Building #101	Faraday	Building #301	Faraday
Building #102	Faraday	Building #302	Faraday
Building #103	Faraday	Building #303	Simplex 4005
Building #104/105	Faraday	Building #304	Simplex 4005
Building #106/107	Simplex 4001	Building #305	Simplex 4005
Building #111	Simplex 2001	Building #306	Simplex 4005
Building #112/113	Simplex 4005	Building #311	Faraday
Building #114	Simplex 4001	Building #312	Faraday
Building #115	Simplex 2001	Building #313	Faraday
Building #201	Faraday	Building #314	Faraday
Building #202	Faraday	Building #315	Faraday
Building #203	Faraday	Building #316	Faraday
Building #204	Faraday		
Building #205	Faraday	Building #401	Faraday
Building #206	Faraday	Building #402/403	Simplex 2001
Building #207	Faraday	Building #404	Faraday
Building #208	Faraday	Building #405/406	Faraday
Building #211	Simplex 2001	Building #411	Faraday
Building #212	Simplex 2002	Building #412	Simplex 4001
Building #213	Faraday	Building #413	Simplex 4002
Building #214	Faraday	Building #414	Faraday
Building #215	Faraday	Building #415	Faraday
Building #216	Simplex 4001		
Building #217	Faraday		
Transition Center	Simplex 4004	Hospital	Simplex 2001
Kitchen 1	Notifier System 500	Adm. Building	Cincinnati 701-202
Kitchen 2	Simplex 2001	Canteen	Cincinnati 701-202
Kitchen 3	Simplex 2001	School Building	Simplex 4005



Attachment C – Equipment List
RFx No. 3000006116 Title: Fire Systems Maintenance
LHH – Pinecrest Supports & Services Center

L & G Café'	Simplex 4005		Crooss Modality	Simplex 4004
BJ Café'	Faraday		A-Building	Cincinnati 701-202
Property Control	Faraday		J-Building	Simplex 2001
Training Center	Cincinnati 701-202		H-Building	Simplex 2001
Psychology Building	Cincinnati 701-202		G-Building	Simplex 2001
Warehouse 1	Cincinnati 701-202		Conference Center	Firelite Sensisanc 5000
Tot's House	Simplex 4002		Monitoring Panel	4100



SCHEDULE II
FREQUENCY OF TESTS AND TEST REQUIREMENTS
FOR EACH FIRE ALARM SYSTEM

<u>TYPE OF DEVICE</u>	<u>TEST FREQUENCY</u>	<u>METHOD</u>
Manual Pull Stations	Semi-Annual 100%	Operate in Alarm
Heat Detector	25% Quarterly, so that all are tested in 1 year	Rate of rise test with
Heat Gun		
Smoke Detectors	25% Quarterly, so that all are tested Annually	Functional test with
approved Aerosol		
Alarm Indicating	Annual	Operate in Alarm
Appliances		
Control Unit	Quarterly	Operate in Alarm and
perform test as		Per NFPA 72H Annunciators
Annunciators	Quarterly	Verify zone labels are correct
Smoke Damper	Quarterly	Operate in Alarm
Tamper Function	Quarterly	



SCHEDULE III

EQUIPMENT STOCK REQUIREMENTS

- A. Replacement Smoke Detectors
 - UL Approved
 - Two or Four Wire Operation
 - Locking Tamper Switches
 - LED Operation and Alarm Indicator
 - Voltage 16-30 VDC/120 Volt AC
 - In stock at all times
- B. Campus Monitoring System
 - CPU (1)
 - CPU Mother Board (1)
 - Power Supply (1)
 - Monitor Board
 - RS232 Printer Board (1)
- C. 4004 Panel Replacement Parts
 - Panel General System Board
 - Monitor Module
 - Signal Module
- D. 4005 Panel Replacement Parts
 - CPU Card
 - Control Relays
 - Monitor Module
 - Signal Module
 - Power Supply
- E. Peripheral Devices
 - Pull Stations (3)
 - Horns 24 VDC (3)
 - Horns AC (3)
 - Visual 24 VDC (3)
 - Visual AC (3)
 - Door Holder AC (1)
 - Door Holder DC (1)



Attachment C – Equipment List
RFx No. 3000006116 Title: Fire Systems Maintenance
LHH – Pinecrest Supports & Services Center

- Tamper Switches
 - 4098-9714 Smoke Detectors
 - 4098-9792 Addressable Base
 - 4099-9004 Addressable Pull Station
- F. 4007ES Panel Replacement Parts
- NAC Power Supply Board
 - 4007 CPU and Display Board
 - Zone/Relay Card
- G. 4100U Panel Replacement Parts
- SPS System Power Supply Card
 - XPS External Power Supply
 - Mother Board and Zone Monitor Card
 - 4100 CPU Mother Board
 - 4100 CPU Card
- H. 4010 Pane Parts
- Main System Board
 - Remote Signal Expander